

## Incident Notification

**Incident Date:** May 27, 2022

**Title:** Reportable Environmental Discharge

**Description:** During cleaning of a sedimentation pond at the Sue Water Treatment Plant, tears in the liner on the bottom of the pond became visible. Sampling showed that some material from the pond was released through the liner to mix with spring runoff. Results indicated elevated concentrations of contaminants of concern.

**Resolution:** Approximately 120 m<sup>3</sup> of water and solids have been pumped out from under the pond for treatment and the liner has been repaired. No effects on health or safety. The effects on the environment will be negligible. Provincial and federal regulators were notified.

