

Incident Notification

Incident Date: June 29, 2022

Title: Reportable Environmental Discharge

Description: An effluent action level exceedance was identified for un-ionized ammonia at the JEB Water Treatment Plant (WTP). The discharge was halted after approximately 15% of the pond volume was released to Sink Reservoir.

Resolution: The remaining effluent in the monitoring pond was recycled. There will be no impact to the environment as a result of this event. Provincial and federal regulators were notified.

