

Incident Notification

Incident Date: March 18, 2023

Title: Propane Release

Description: The maintenance team was called to the packaging warehouse due to a strong smell of propane in the area. Upon arrival, maintenance discovered that the safety shut off valves in the HVAC unit had failed open and were allowing the combustion chamber/duct work to fill up with propane vapor.

Resolution: The unit was immediately isolated. As these shut off valves are not serviceable, the unit was locked out until a replacement valve is received. No one was injured and there was no impact on the environment. Provincial and federal regulators were notified and an investigation into the incident commenced.

