

Incident Notification

Incident Date: January 24, 2025

Title: **Dangerous Occurrence - Punctured Electrical Cable with Drill Bit**

Description: A worker was drilling a hole on an interior wall to install a new wastewater line. During the drilling process, the worker encountered resistance and backed the drill out. Upon inspection, it was revealed that a 120-volt electrical cable feeding power to a wall plug had been damaged.

Resolution: Work was stopped and the incident reported to the supervisor. No sparks or arcing were observed as the breaker tripped as designed. There were no effects on the environment, health or safety. Regulators were notified and an investigation is ongoing.

