

Incident Notification

Incident Date: March 25, 2024

Title: **Dangerous Occurrence – Ferric Reactor**

Description: While contractors were working on repairs to ferric reactor #1, a leak of hot ferric solution was noticed on ferric reactor #2, which was recently repaired. Steam and ferric discharged from the pressurized vessel. Workers relieved the pressure and the area was barricaded and ventilated.

Resolution: There were no effects on the environment and no injuries. Federal and provincial regulators were notified. An investigation is on-going and a follow up report will be submitted to regulatory agencies.

