

Incident Notification

Incident Date: October 3, 2024

Title: **Dangerous Occurrence - Ammonia**

Description: On October 3rd, ammonia was released into the strip cells area of SX2. The area alarms activated and operators quickly identified the hazard and left the area. Operators donned respirators and stopped the ammonia release by remotely closing the valve from the control room. No exposures were identified.

Resolution: The ammonia flow was stopped and the upstream valve was closed and locked out. The area was partitioned with danger tape and ventilated. There are no effects on the environment, health or safety. Federal and provincial regulators were notified. An investigation is on-going and a follow up report will be submitted to regulatory agencies.

