

Incident Notification

Incident Date: February 18, 2025

Title: **Dangerous Occurrence – Propane Spill on Mill Terrace**

Description: After noticing the smell of propane, a worker investigated and discovered a broken ball valve and broken pressure gauge on a line in the propane pump shack with liquid propane released onto the floor. The employee isolated the leak to stop the discharge and left the shack. Liquid propane was found on the floor of the shack and frozen on the piping and pumps.

Resolution: The Emergency Response Team was activated to draft a Safe Work Plan to safely remove the discharged propane. There were no injuries and the effects on the environment will be negligible. The area was barricaded and the Safe Work Plan used to clean up the discharged propane inside the shack. Regulatory agencies were notified and an investigation is ongoing.

