

Incident Notification

Incident Date: June 1, 2021

Title: **Effluent Discharge Action Level Exceedance**

Description: An effluent discharge level exceedance was identified for total suspended solids (TSS) at the JEB Water Treatment Plant (WTP) for the previous 24-hour sample. The effluent discharge action level is 22.5 mg/L and the sample returned a TSS result of 25 mg/L.

Resolution: Further discharge from the JEB WTP was halted and additional samples will be collected from the three subsequent ponds before discharge. All returned results were well below the TSS administrative level (which is below the action level). The effect on the environment will be negligible. Orano is investigating the circumstances. Provincial and federal regulators were notified and a follow-up report will be submitted.

